R.L. Harris Dam Relicensing - FERC No. 2628 Reservoir Operations on the APC Hydro System

Presented by:

Alan Peeples Manager – Reservoir Management

January 31, 2018 Wedowee Marina South





First Things First



Power



Power - Capacity

- Installed capacity is the maximum instantaneous power that a generating unit can produce, and is expressed in megawatts (mw)
 - the power the unit is generating at any one moment in time
 - Harris installed capacity is 66mw per unit
 - Instantaneous Load (mw)
 - Electricity is a demand product
 - Instantaneous Load is the instantaneous demand for electricity on the system.
 - Harris' installed capacity supports the instantaneous demand (load) on the Southern Electric bulk power system

Power - Energy Generation

- the electricity generated over a period of time (one hour), expressed as megawatt hours.
 - 1 mwh = 1,000 kwh
 - Your power bill is based on electricity usage, measured in kwh



Hydroelectric Dams are both producers and consumers of energy

Production

• Generating electricity for consumer end use

Consumption

- Station service measured in mwh
 - The local energy needed at the dam to run pumps, lights, compressors, etc. for operations
- "Motoring" a big heat sink
 - Systemwide benefits for electric grid stabilization



Hydraulics



Hydraulic Capacity

There are 2 primary ways to pass water from the dam:

- 1. Hydroelectric Generating Unit Operation
 - Electricity is generated
- 2. Spill Gate Operation
 - No electricity is generated, only passing water

Under normal conditions, spill gates are not operated until all of the available generating units are at full gate flow



Hydraulics



Hydraulic Capacity - Hydroelectric Generating Unit Operation

- Hydraulic capacity is the flow, cubic feet per second (cfs), that a hydroelectric generating unit is designed to pass
 - Best Gate flow the amount of flow from the unit at the most efficient wicket gate position
 - This is where the unit is operated under normal conditions
 - ~6500 cfs
 - Optimum balance between power and flow
 - Best MPG
 - Full Gate flow the amount of flow from the unit with wicket gates in the 100% (wide open) position
 - ~8000 cfs
 - Moves the most water but not most efficient generating point, less energy production
 - i.e., non-optimal MPG
 - Operated when there is a greater need to move larger quantities of water
 - High flow situations



Hydraulics



Hydraulic Capacity – Spill Gate Operation

- The spillway section where the spill (tainter) gates are located is 310 feet long and contains six tainter gates, each 40.5 feet wide and 40.0 feet high.
- The spillway crest is at elevation 753.0 msl
- The top of the tainter gates is elevation 793.5 msl, one-half foot above full summer pool
- At elevation 795.0 msl, the upper limits of the Induced Surcharge Curve, the spillway has a capacity of almost 270,000 cfs.



Flow versus Volume

- Flow is a volume of water per unit of time
 - For example
 - Cubic feet per second, cfs
 - 1 cfs = 448.8 gallons per minute (gpm)
- Volume is the result of flow over time
 - For Hydro, it is calculated as day-second-feet or dsf
 - 1 cubic foot per second for one day
 - 1 dsf = 1 cfs x 86400 seconds/day = 86400 cubic feet
 - 1 dsf = 646,272 gallons
 - 1dsf = 1.983 acre-feet (1.983 feet deep over an acre)
 - also referred to as cfs-day

Example

- Harris Unit 1 operates for 12 hours of the 24 hour day
- Volume is 6500 cfs x 12 hours / 24 hours = 3250dsf
- Could also consider this 3250cfs average for day









the Leading Renewable Energy Source

According to the U.S. Energy Information Administration (EIA):

- Generation from Renewable Fuels
 - "Hydroelectric. Water is currently the leading renewable energy source used by electric utilities to generate electric power".
 - Hydropower accounted for **6.5%** of total U.S. electricity generation and **44%** of generation from renewables in 2016.



Hydropower Installed Capacity





2012 Capacity (MW)		
 Washington 	21,112	
2 California	10,057	
3 Oregon	8,241	
4 New York	4,657	
6 Alabama	3,280	
6 Arizona	2,718	
🕖 Montana	2,655	
8 Idaho	2,540	
9 Tennessee	2,499	
🕼 North Carolina	1,939	







Source: U.S. Energy Information Administration, *Renewable Energy Consumption and Electricity Preliminary 2009 Statistics* (August 2010).







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 13.B (March 2011).







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.13.B (February 2012).







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.13.B (February 2014).







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.13.B (February 2014).







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.13.B (February 2015)







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.13.B, preliminary data, February 2016







Source: U.S. Energy Information Administration, *Electric Power Monthly*, Table 1.10.B, February 2017, preliminary data





Alabama Power 2016 Energy Mix

Generation (kilowatt-hours) percentages*				
Coal	52.50%			
Nuclear	22.66%			
Oil and Gas	19.54%			
Hydro	5.30%			



POTENTIAL ENERGY



From Water to Electric Power









P(kW) = (WxHxQxT)/737xTP(kW) = (62.5xHxQxT)/737xTP(kW) = (HxQ)/11.8

Two factors dictate how much power is available for production: H (Head) and Q (Flow)







Alabama Power Company

Hydroelectric Generation

- 14 Powerhouses
 - 41 Units
 - ~ 1600 megawatts of capacity
- 11 Reservoirs
 - 170,000 acres of pool area
 - 3,500 miles of shoreline
- Located in the Black Warrior, Coosa and Tallapoosa Basins



Competing Needs

- Power Generation
 - Energy
 - Bulk Power System Dynamic Benefits
- Flood Control
- Navigation
- Recreation
- Ecological / Water Quality
- Water Supply
 - Municipal
 - Industrial
 - Agricultural



Regulatory Flows

FERC

Project License

- Minimum Flows
 - Coosa
 - Jordan 2000+ cfs
 - Recreation Flows
 - Tallapoosa
 - Harris (Wadley) 45cfs
 - Thurlow 1200 cfs
 - Warrior
 - Smith 50cfs

U.S. Army Corps of Engineers

Reservoir Regulation Manuals

- Operate for Flood Control
- Provide for Navigation
 - Alabama River
 - 4,640 cfs
 - Warrior River
 - 245 cfs (Smith)



Flood Control License Articles



Coosa

 <u>Article 402</u>. Flood Control Operations at Weiss, Neely Henry, and Logan Martin Developments. The purpose of this article is to provide for flood control in accordance with rules and regulations prescribed by the Secretary of the Army pursuant to Public Law 83-436.

Warrior

<u>Article 403</u>. Flood Control Operations. Upon issuance of this license, the licensee shall operate the Smith development in accordance with the U.S. Army Corps of Engineers (Corps) March 1965 Black Warrior-Tombigbee River Basin Reservoir Regulation Manual, Appendix A, for the Lewis M. Smith Reservoir (Manual), unless otherwise directed by the Corps

<u>Harris</u>

<u>Article 13(c)</u> Operate the reservoir for flood control in accord with the agreement between the Chief of Engineers Department of the Army...

Martin

• <u>Article 404</u>. *Flood Control Operations.* The licensee must operate the project such that Lake Martin does not exceed elevation 491 feet mean sea level (msl) to assist in flood control. Flood control operation must be guided by the following: ...



...as Prescribed by Secretary of the Army



- U.S. Army Corps of Engineers, Mobile District
 - Basin-wide Master Reservoir Regulation Manuals
- Alabama–Coosa-Tallapoosa River Basin Reservoir Regulation Manual
 - Appendix B Weiss
 - Appendix C Logan Martin
 - Appendix D Henry
 - Appendix I Harris
- Black Warrior Tombigbee River Basin Reservoir Regulation Manual
 - Appendix A Smith



Navigation Support Releases



to meet a 9.0-Foot Navigation Channel					
Month	APC navigation Target (cfs)	Monthly historic storage usage (cfs)	Required basin inflow (cfs)		
Jan	9,280	-994	10,274		
Feb	9,280	-1,894	11,174		
Mar	9,280	-3,028	12,308		
Apr	9,280	-3,786	13,066		
May	9,072	-499	9,571		
Jun	8,648	412	8,236		
Jul	8,232	749	7,483		
Aug	7,808	1,441	6,367		
Sep	7,600	1,07 1	645		
Oct	7,600	2,18	6 , 4 2		
Nov	8,024	29C-1	571		
Dec	8,864	1,789	7,0 5		

Table 7-2 Basin Inflow above APC Projects Required

Table 7-3. Basin Inflow above APC Projects Requiredto meet a 7.5-Foot Navigation Channel

Month	APC navigation Target (cfs)	Monthly historic storage usage (cfs)	Required basin inflow (cfs)
Jan	7,960	-994	8,954
Feb	7,960	-1,894	9,854
Mar	7,960	-3,028	10,988
Apr	7,960	-3,786	11,746
May	7,856	-499	8,355
Jun	7,648	412	7,236
Jul	7,432	749	6,683
Aug	7,224	1,441	5,783
Sep	7,120	1,025	6,095
Oct	7,120	2,118	5,002
Nov	7,328	2,263	5,065
Dec	7,752	1,789	5,963



What are the issues to be considered?

During certain storm trouble, hydro can quickly resolve associated line overloads

Provide "backup generation" during sudden loss of a generating unit

Provide "blackstart" capabilities to system

Provide "voltage stabilization" as system load changes throughout the day

Operating flexibility is important in APC's ability to provide low cost, reliable electric service to its customers



All Energy Production Requires a Fuel Source

Our Fuel Procurement Contract...





30-yr Normal Precipitation: Annual Period: 1981-2010



Tallapoosa Basin Average Monthly Rainfall



MONTH





WEEK OF THE YEAR


Hurricanes and Tropical Storms Hurricanes

NOAA

Informed Decision Making

How Do We Know What We Need to Know to Operate?





wil-ly-nil-ly

adverb 1. without direction or planning; haphazardly.

synonyms: haphazardly, at random, randomly, every which way, here and there, all over the place, in no apparent order











U.S. Seasonal Drought Outlook Drought Tendency During the Valid Period

Valid for January 18 - April 30, 2018 Released January 18, 2018



Depicts large-scale trends based on subjectively derived probabilities guided by short- and long-range statistical and dynamical forecasts. Use caution for applications that can be affected by short lived events. "Ongoing" drought areas are based on the U.S. Drought Monitor areas (intensities of D1 to D4).

NOTE: The tan areas imply at least a 1-category improvement in the Drought Monitor intensity levels by the end of the period, although drought will remain. The green areas imply drought removal by the end of the period (D0 or none).

Drought persists

Drought remains but improves

Drought removal likely

Drought development likely



http://go.usa.gov/3eZ73

U.S. Drought Monitor Alabama

January 23, 2018

(Released Thursday, Jan. 25, 2018) Valid 7 a.m. EST





The Drought Monitor focuses on broad-scale conditions. Local conditions may vary. See accompanying text summary for forecast statements.

Author:

Richard Heim NCEI/NOAA



http://droughtmonitor.unl.edu/





Sunday, January 28, 2018



Map of 14-day average streamflow compared to historical streamflow for the day of the year

High

No Data





We are a Data Driven Function

How Do We Know What We Need to Know to Operate?







• HDAS – Hydro Data Acquisition System

 HOMS – Hydro Optimization Management System



HDAS Remote Gage Network



Hydro Optimization Management System HOMS

- Three Systems Production, Backup and Development
- Twenty Three Servers
- Seven Database Servers and Twenty Databases
- Six Web Sites
- Six Desktop Applications

Gaging Program – Electronic Gages









Two Types of Reservoirs:

- Run of River
- Storage



Run of River:



- What flows in, also flows out
 - Inflow = Releases
 - Substantially consistent lake level year round Coosa
 - Lay
 - Mitchell
 - Jordan/Bouldin

Tallapoosa

Yates/Thurlow



Alabama Power - Lay



Elevations (MSL)

Copyright 2018 Alabama Power Plotted@1/29/2018 1:22 PM

Elevations (MSL)

Year 2018

Storage Reservoirs



- What flows in, doesn't necessarily flow out or what doesn't flow in may actually flow out
 - Different Summer and Winter Elevations
 - Coosa
 - Weiss
 - H. Neely Henry
 - Logan Martin
 - Tallapoosa
 - Harris
 - Martin
 - Warrior
 - Smith
 - Critical for Flood Control
 - Critical for Drought Mitigation



Alabama Power - Harris



Copyright 2018 Alabama Power Plotted@1/31/2018 5:22 AM

Elevations (MSL)

Year 2018

Hot Dogs and Energy Production







Peaking Generation



- Water available for generating electricity is limited
- Hydro is operated to fill in the peak load demand
 - Maximizes economics
- Summer has one peak
 - •around 3 pm
- Winter has two peaks
 - Morning around 7 a.m.
 - •Afternoon around 7 p.m.







Hour

Harris Specific Operations



Routine Operations

Flood Operations

Drought Operations



Tallapoosa River Basin



Tallapoosa River Basin

Approx. 1450 square miles of watershed draining into the reservoir









Alabama Power - Harris



Copyright 2018 Alabama Power Plotted@1/29/2018 1:22 PM

Year 2018

Designed for Peaking Operations



Harris Adaptive Flow – Green Plan - Main Unit Pulses

Create schedule based on prior day's Heflin flow

STEP	Prior Day's Heflin Flow (dsf)	Generation At 6 AM	Generation At 12 Noon	Generation As System Needs	Total Machine Time	Harris Total Discharge (dsf)
1A	0 < Heflin Q < 150	10 min	10 min	10 min	30 min	133
2A	150 < Heflin Q < 300	15 min	15 min	30 min	1 hour	267
3A	300 < Heflin Q < 600	30 min	30 min	1 hour	2 hours	533
4A	600 < Heflin Q < 900	30 min	30 min	2 hours	3 hours	800
5A	900 < Heflin Q	30 min	30 min	3 hours	4 hours	1,067

Adjust Schedule if Necessary

STEP	Total Schedule Generation	Generation At 6 AM	Generation At 12 Noon	Generation As System Needs	Total Machine Time	Harris Total Discharge (dsf)
1B	If generation = 1 machine hr	15 min	15 min	30 min	30 min	267
2B	If generation = 2 machine hr	30 min	30 min	1 hour	1 hour	533
3B	If generation = 3 machine hr	30 min	30 min	2 hours	2 hours	800
4B	If generation = 4 machine hr	30 min	30 min	3 hours	3 hours	1,067
5B	Generation > 4 machine hr	Not Required	Not Required	ALL		

Create Schedule	Ad	Additional Generation			Adjust Schedule		
		Needed					
Harris Discharge					Har	ris Disc	charge
30 min, 30 min, 3 h	ours				No Puls	sing Re	quired
Harris Discharge					Har	ris Disc	charge
30 min, 30 min, 2 h	ours			30	min, 30	min, 3	hours
Harris Discharge					Har	ris Disc	charge
30 min, 30 min, 1 h	our			30	min, 30	min, 2	hours
Harris Discharge					Har	ris Disc	charge
15 min, 15 min, 30	min			30) min, 3	0 min,	1 houi
Harris Discharge					Har	ris Disc	charge
10 min, 10 min, 10	min			15	min, 1	5 min, 3	30 mir
8 9/9 9/10	9/11 9/	12 9/	13 9/	14 9/	/15 9/	16 9/	17

Heflin Flow (cfs)







Weather Extremes!

Floods and Drought


Harris Dam – May 2003

Floods





Flood Control



- Flood Control can be defined as minimizing river stages downstream of a dam
 - Generally, the people and property located downstream benefit from flood control operations
- Run-of-river reservoirs have no flood control capability
 - they cannot provide this benefit to the public
- Most flood control reservoirs have a control point that is used as a focus for the flood control operations:
 - Harris uses Wadley



How Are Floods Managed



- Downstream flood peaks are minimized by discharging less water than is coming into the reservoir
- Studies of historic rainfall events result in a reasonable rules and regulations (flood control plan)
- Not every flood can be completely controlled
 - each project has a particular amount of water that it can store
 - after all flood storage has been used, the project becomes run-of-river



License for FERC Project 2628



• Article 13. (c) Operate the reservoir for flood control in accord with the agreement between the Chief of Engineers, Department of the Army, and the Licensee ...



Appendix I - R. L. Harris Dam and Lake



US Army Corps of Engineers ® Mobile District

ALABAMA-COOSA-TALLAPOOSA RIVER BASIN WATER CONTROL MANUAL

Final APPENDIX I

R. L. HARRIS DAM AND LAKE (ALABAMA POWER COMPANY)

TALLAPOOSA RIVER, ALABAMA

U.S. ARMY CORPS OF ENGINEERS SOUTH ATLANTIC DIVISION MOBILE DISTRICT MOBILE, ALABAMA

SEPTEMBER 1972 REVISED OCTOBER 1993; JUNE 2004; and MAY 2015

Harris Reservoir Flood Control Procedure

Rule	Condition	Outflow	Operation
1	Below Power Guide Curve (PGC)		Operate powerplant to satisfy system load requirements.
2	At or above PGC and below elevation 790	13,000 cfs or less depending on Wadley stage	Operate to discharge 13,000 cfs or an amount that will not cause the gage at Wadley to exceed 13.0 feet, unless greater discharge amounts are required by the Induced Surcharge Schedule. Discharge rates determined by the Harris real-time water control model may be substituted for those indicated by the Induced Surcharge Curves. If the model produces outflows in excess of those identified by the Induced Surcharge Schedule for six (6) consecutive periods, the operator shall notify the Water Management Section before making any further gate movements.
3	Above PGC and above 790 and rising	16,000 cfs or greater	Discharge 16,000 cfs or greater if required by the Induced Surcharge Curves Releases may be made through the spillway gates or powerhouse or a combination of both. Discharge rates determined by the Harris real-time water control model may be substituted for those indicated by the Induced Surcharge Curves. If the model produces outflows in excess of those identified by the Induced Surcharge Schedule for six (6) consecutive periods, the operator shall notify the Water Management Section before making any further gate movements.
4	Above PGC and falling		When the reservoir begins to fall, maintain current gate settings and power house discharge until the pool recedes to the PGC, then return to normal operation.

Induced Surcharge Curves

CORPS OF ENGINEERS



to those prescribed under this schedule.

U. S. ARMY







MAY 8, 2003

ON THIS DAY, WATER FROM THE TALLAPOOSA RIVER ROSE TO THIS LEVEL AT THIS LOCATION. FOR MORE INFORMATION, CONTACT:

NATIONAL WEATHER SERVICE BIRMINGHAM, AL www.srh.noaa.gov/bmx

SOUTHEAST RIVER FORECAST CENTER weather.gov/serfc

USGS ALABAMA WATER SCIENCE CENTER al.water.usgs.gov

100.641



No. Haddel



Responsibility for issuing stage forecasts to the public







WDLA1(plotting HGIRG) "Gage 0" Datum: 599.87'

Observations courtesy of US Geological Survey

Tallapoosa River at Wadley



Flood Impacts

- 35 THE EAST END OF THE HIGHWAY 22 BRIDGE BEGINS TO FLOOD. WATER REACHES STORE/GAS STATION ON HIGHWAY 22 JUST WEST OF TOWN.
- 32 PORTIONS OF HIGHWAY 22 SOUTHWEST OF WADLEY ARE FLOODED.
- **30** SOME FLOODING OF BUSINESSES...INCLUDING PLANTATION PATTERNS...OCCURS IN THE WADLEY AREA.
- 20 SOME FLOODING OCCURS IN THE WADLEY AREA. BETWEEN 22 AND 25 FEET THE BRIDGE OVER BEAVERDAM CREEK FLOODS.
- 13 FLOODING OF PASTURELANDS IN THE AREA OCCURS AND CATTLE SHOULD BE MOVED TO HIGHER GROUND.

Low Water Impacts

• 45 CFS R.L. Harris dam (15 miles upstream) operated to provide a minimum flow of 45 cfs at Wadley.



Droughts

U.S. Drought Monitor Alabama





October 16, 2007

(Released Thursday, Oct. 18, 2007) Valid 7 a.m. EST

Drought Conditions (Percent Area)

	None	D0-D4	D1-D4	D2-D4	D3-D4	D4
Current	0.00	100.00	99.97	93.23	83.12	73.04
Last Week 10/9/2007	0.00	100.00	99.97	91.01	78.18	58.82
3 Month s Ago 7/17/2007	0.00	100.00	90.28	71.55	41.56	24.33
Start of Calendar Year 1/2/2007	51.87	48.13	0.00	0.00	0.00	0.00
Start of Water Year 9/25/2007	1.40	98.60	90.18	81.92	71.11	48.72
One Year Ago 10/17/2006	0.00	100.00	57.95	0.00	0.00	0.00

Intensity:



D0 Abnormally Dry

D3 Extreme Drought D4 Exceptional Drought

The Drought Monitor focuses on broad-scale conditions. Local conditions may vary. See accompanying text summary for forecast statements.

Author:

Mark Svoboda National Drought Mitigation Center



http://droughtmonitor.unl.edu/



Drought Management



- Droughts are very difficult to see coming
 - you don't know you're in a severe drought until you've been there for some time
- Droughts tend to take months to setup
 - And take months of wet weather to return flow conditions to normal
- APCo's storage reservoirs can, to an extent, support some level of critical downstream flows during drought periods
 - this is done by releasing water from storage
- How does APCo determine how much and when and from where?
 - Alabama-ACT Drought Response Operating Plan (ADROP)
 - a low flow management plan, not a plan to keep the lakes full



ADROP October 2016 Re

Table 3: Drought Intensity Level Response Matrix¹

rought Isity Level—	ers	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	
		Normal Operations												
	100	DIL 1: Low Basin Inflows or Low Composite Storage or Low State Line Flow												
	F	DIL 2: DIL 1 criteria + (Low Basin Inflows or Low Composite Storage or Low State Line Flow)												
-		DIL 3: Low Basin Flows + Low Composite Storage + Low State Line Flow												
Coose	River Flow ²	Normal Operations 2000 cfs			4000 (8000) 4000 - 2000			Normal Operations 2000 cfs						
		Jordan 2000 +/- cfs		Jordan 4/7 4000 +/- cfs 8/8			Jordan 2000 +/- cfs		Jordan 2000 +/- cfs					
		Jordan 2000 +/- cfs 25		Jordan Ur i00 +/- cfs			Jordan 2000 +/- cfs		Jordan 2000 – 1600 +/- cfs					
		Jordan 1600 +/- cfs 16			Jordan 00 - 2000 +/- cfs			Jordan 2000 +/- cfs		Jor 1800	dan +/- cfs	Jordan 1600 +/- cfs		
Tallapoosa	[Normal Operations 1200 cfs												
	ver Flow ³	Greater of: ½ Yates Inflow or 2 x Heflin Gage (Thurlow releases > 350 cfs)				½ Yates Inflow					½ Yates Inflow			
		Thurlow 350 cfs					½ Yates Inflow					Thurlow 350 cfs		
	ž	Maintain 400 cfs at Montgomery WTP (Thurlow release 350 cfs)						Thurlow 350 cfs			Maintain 400 cfs at Montgomery WTP (Thurlow release 350 cfs)			
Alabama	Normal Operations 4640 cfs													
	-,	4200 cfs (10% Cut) - Montgomery						540 cfs - Montgo	mery	Reduce 4640 cfs – 4200 cfs Montgomery				
	er Flov	3700 cfs (20% Cut) - Montgomery					4200 cfs (10% Cut) - Montgomery					Reduce: 4200 cfs - 3700 cfs Montgomery (1 Week ramp)		
	Rive	2000 cfs Montgomery				3700 cfs Montgomery		4200 cfs	4200 cfs (10% Cut) Montgomery		Reduce 4200 cfs - 2000 cfs Montgomery (1 Month ramp)			
de Curve	[Nor	rmal Operations	: Elevations fo	llow Guide	urves as prescrit	oed in License (Measured in F	eet)			
	<u></u>	USACE Variances: As Needed: FERC Variance for Martin												
	eval	USACE Variances: As Needed; FERC Variance for Martin												
Guì		USACE Variances: As Needed; FERC Variance for Martin												

1. Note these are base flows that will be exceeded when possible

Jordan flows are based on a continuous +/- 5% of target flow
Thurlow flows are based on a continuous +/-5% of target flow, Flows are reset on noon each Tuesday based on the prior day's daily average at Heflin or Yates

4. Alabama River flows are 7-Day Average Flow

EVAPORATION



- Evaporative losses amounted to 1.5 feet of water from Alabama Power lakes in the summer months of 2007
- Enough water to supply Birmingham for one year



Alabama Power - Harris



Plotted@1/31/2018 5:22 AM

Year 2018

Alabama Power - Harris



Our Agency Partners in Water Management NATIONAL OCEANIC AND NATIONAL OCEANIC AND ATMOSPHERIC ADMINISTRATION

Alabama Department of Environmental Management







A Division of ADECA









Questions?

